



- Technical Requirements:
1. Cabinet shell and door is connected with hinges and the door and hinges are connected through using d3.2 blind rivets(per picture shown);
 2. When the cabinet is locked in close, the door shall be flush with cabinet; and the door opening angle shall be more than 180°; ã;
 3. When there is no key to open and in urgent use, just break the wire glass and directly open the latch lock by hand from inside.

10	DLX01-036-03-Y01	Marking	1				
9	GB/T818-2000	M4 × 16 Pan head screw	3	Steel			Galvanized
8	DLX02-037A	Latch lock	1	Assembly			
7	DLX01-036-03	Wire glass	1	Glass 575 × 332 × 6mm			
6	GB/T6182-2000	M5 Hexagon locking nut	6	Copper			Nickel plating
5	DLX02-039A	Press plate	1	SUS304			
4	DLX01-037A-02	Door	1	SUS304			
3	GB12618-90	Blind rivet d 3.2	10	Aluminium			
2	DLX02-024	Hinge	1	SUS304			
1	DLX01-037A-01	Cabinet shell	1	SUS304			
No.	Drawing No.	Name	QTY	Material	Weight	Remark	
			630 × 460 × 80	Code No.	HC005		
			Stainless Steel Fire Cabinet				
Zone			Revision note	Date	Signature	Assembly	
Drawn		Audit				W.T.	
Checked		Approval				Scale	
						Hydrotech	