



Technical Requirements:

1. Cabinet shell and door is connected with hinges and the door and hinges are connected through using d3.2 blind rivets(per picture shown);
2. When the cabinet is locked in close, the door shall be flush with cabinet; and the door opening angle shall be more than 180°;
3. When there is no key to open and in urgent use, just break the wire glass and directly open the latch lock by hand from inside.

10	DLX01-035-03-Y01	Marking	1		
9	GB/T818-2000	M4×16 Pan head screw	3	Steel	Galvanized
8	DLX02-037A	Latch lock	1	Assembly	
7	DLX01-042-03	Wire glass	1	Glass 465×340×6mm	
6	GB/T6182-2000	M5 Hexagon locking nut	6	Copper	Nickel plating
5	DLX02-039	Press plate	1	1.5mm color zinc plate	
4	DLX01-042-02	Door	1	Cold rolled low carbon steel	
3	GB12618-90	Blind rivet d 3.2	8	Aluminium	
2	DLX02-040	Hinge	1	SUS304	
1	DLX01-042-01	Cabinet shell	1	Cold rolled low carbon steel	
No.	Drawing No.	Name	Q'TY	Material	Remark
			395×595×295	Fire Cabinet	Code No.
					HC010

Zone	Revision note	Date	Signature	Assembly	W.T. ~14.5Kg	Scale
Drawn						
Checked	Approved					
					Hydrotech	