



**Technical Requirements:**

1. Hinge installation per drawing shown;
2. In closing status, door and frame shall be flush and the opening angle of door shall achieve 180 degrees;
3. During urgent situation and no key to open the door, the wire glass can be broken and then open the door from inside by hand.

11	DLQ03-150	Packing carton	1	Double Corrugated Carton		
10	DLX01-054-03	6mm wire glass	1	518×240×6mm		
9	GB/T818-2000	M4×16 head screw	3	Steel		Zinc plated
8	DLX02-037A	Latch lock	1	Assembly		
7	DLX01-035-03-Y01	Label	1			

No.	Drawing No.	Name	QTY	Material	Weight	Remark
6	DLX01-054A-02	Door frame	1	SUS304		
5	GB/T6182-2000	M5 hexagon locking nut	6	Brass		Bright nickel plated
4	DLX02-039A	Press plate	1	SUS304		
3		M8 cross recess head screw	8	Steel		Zinc plated
2	DLX02-065	Hinge	1	Assembly		
1	DLX01-054A-01	Cabinet shell	1	SUS304		

Zone		Revision note		Date		Signature	
Drawn		Audit					
Checked		Approved					
Surface mounted fire cabinet				Code No.		HC023	
Assembly				W.T.		~13Kg Scale	
				Hydrotech			