



- Technical requirements:
1. When 1" joint is connected with valve body and 1" gate valve, it shall be sealed with thread sealant;
  2. Inlet flange at the bottom is DN100, per standard BS 4504(PN16);
  3. No leakage, destruction and eternal deformation will be caused after tested at water pressure of 20bar.

7	DLS01-064-06	1" Joint	2	Steel(Nickel Plating)		
6	DLV05-002-00	1" Gate valve	1	Assembly		
5	DLS01-064-05	Aluminium cap	1	6061		
4	DLS01-064-04	Chain	1	SUS 304		
3	DLS01-064-03	Cap	2	Rubber		
2	DLS01-064-02-00	Connecting seat	2	Assembly		
1	DLS01-064-01	Valve body	1	Ductile iron		
No.	Drawing No.	Name	Q'TY	Material	Weight	Remark
			Two Way Inlet Breaching Valve (BS4504)			
			Code No. HV008			
			W.T. ~14.25Kg Scale			
			<b>Hydrotech</b>			
Zone	Revision note	Date	Signature			
Drawn						
Checked	Approved					